

REQUEST FOR TENDER RFT 2418 ADDENDUM #2

St. Alban's Nursery Two Childcare

Issued January 27, 2025

This Addenda shall become part of the Request for Tender (RFT) documents. The information contained in the addendum supersedes and amends the RFT documents and previous addenda, and Bidders are solely responsible to ensure they have received, and that their Tender incorporates, all addenda issued prior to RFT closing, and all costs resulting from such addenda.

General

1. The tender closing date and time is February 4th at 4:00 pm.
2. A revised Bid Form (Rev 2) is provided with this addendum with the correct submission date, and it must be used for the submission of Bids.
3. A second site review will take place Tuesday January 28th at 10:00. This second site visit is primarily to allow asbestos abatement contractors to review the site now that the DSS Report has been issued. This is not a mandatory site visit.

Architectural

1. Underlayment: Supply and install ¼" mahogany or fir underlayment in Room 015 on top of the insulated sub-floor panels and prepare as required for the installation of the flooring. The door frames will be set based on the floor height of the room (doors not undercut). The details of the floor transitions to be worked out at time of construction.
2. Chain Link Fence: The chain link fencing shall be 9 gauge, residential grade, with 1 ½" diamonds (heavier grade metal).

End of Addendum #2