



Suite 218
5468 Dundas St. West
Islington, Ontario
M9B 6E3

Tel: (416) 233-1201
Fax: (416) 233-1202

Principal

Gino Natale
B. Arch. OAA, MRAIC

PROJECT: NEW TWO STOREY RESIDENTIAL BUILDING:
CANNINGTON AFFORDABLE HOUSING FOR SENIORS
100 McKay Street, Cannington, Ontario

PROJECT NO: 16-16

SUBJECT: RFI NO: 12

DATE: August 21, 2018

Area/Description/Subject:

Mechanical

Reference Drawings/Specification No:

Mechanical Drawings/Specifications

Information Requested:

1. Is IPEX an acceptable product to use in this project's plumbing supply installations?
2. On drawing M-7, it states domestic copper piping to be Type L, however in section 224210, 2.5, Type M is specified.
3. Is System 15/XFR an acceptable product to use for buried drainage and sanitary sewer piping?

Responses:

1. PEX-A is acceptable for plumbing supply.
2. Type L copper is to be used.
3. System 15 PVC is an acceptable product for buried drainage.

END